

Document Log Item

Addressing			
From		To	
Sara Greiner/R9/USEPA/US		"Steven Costa" <glatzeldacosta@suddenlink.net>	
CC		BCC	
Carl Goldstein/R9/USEPA/US@EPA "Edna Buchan" <ebuchan2@yahoo.com> "Karen Glatzel" <kargatgdc@suddenlink.net> "Peter Peshut" <pjp617@uow.edu.au>			
Description			Form Used: Reply
Subject		Date/Time	
Re: Request to Revise WQCs.doc		11/01/2007 02:18 PM	
# of Attachments	Total Bytes	NPM	Contributor
1	44,274		Marcela VonVacano
Processing			
Comments			

Body

Document Body

Hi Steve,

Just had a chance to look at the canneries request for a larger mixing zone for ammonia. Just wanted to note that your calculation is correct in determining the waste load allocation of 102 mg/l based on the chronic criteria for ammonia (i.e., 0.33 mg/l). But I just wanted to add that, as described in the fact sheets, EPA is using the statistical procedure for determining the MDL and AML. So, the MDL and AML would look more like 167.27 and 83.36 mg/l, respectively, if the 313:1 dilution is approved by ASEQC. If approved, I will be revising the permits to include these numbers. As far as compliance with the AML, it doesn't appear from the DMR data that StarKist

should have a problem with complying with this number. If fact, the monthly ammonia numbers are much lower than that. For COS, I do not have any monthly data.

Let me know if you have any questions.

sng

Sara N. Greiner
U.S. Environmental Protection Agency
Clean Water Act Standards and Permits Office
75 Hawthorne Street, WTR-5
San Francisco, California 94105
Telephone: 415-972-3042
Fax: 415-947-3545

"Steven Costa" <glatzeldacosta@suddenlink.net>

"Steven Costa"
<glatzeldacosta@suddenlink.net>

10/28/2007 05:46 PM

Please respond to "Steven Costa" <glatzeldacosta@suddenlink.net>
--

To "Edna Buchan" <ebuchan2@yahoo.com>, "Peter Peshut"
<pjp617@uow.edu.au>
cc Carl Goldstein/R9/USEPA/US@EPA, Sara Greiner/
R9/USEPA/US@EPA, Robyn Stuber/R9/USEPA/
US@EPA, "Tim Ruby" <Tim.Ruby@delmonte.com>,
"Jim Cox" <jcox@cosintl.com>, "Joe Carney"
<Joe.Carney@delmonte.com>, "Ken McLeod"
<kmcleod@sampac.com>, "Karen Glatzel"
<kargatgdc@suddenlink.net>

Subject Request to Revise WQCs.doc

Edna, Peter

Attached is the canneries request to revise the water quality certification to include a mixing zone for ammonia that is based on the chronic criterion. Let us know if this is sufficient or if you need a more detailed description. A signed original is in the mail for your files, but Sara would like to get resolution on this as soon as possible.

Steve and Karen

Steve Costa
Karen Glatzel
216 Driftwood Lane
PO Box 1238
Trinidad, CA 95570-1238

slcatgdc@earthlink.net

-



glatzeldacost@suddenlink.net Request to Revise WQCs.doc